DESIGN AND PERFORMANCE ANALYSIS OF SHELL AND TUBE HEAT EXCHANGER

A Project

by

RIAD FERDOUS

MARK PIAL HALDER

MAHEDI HASAN

MD. NURUNNABE

MAHEDI HASAN



DEPARTMENT OF MECHANICAL ENGINEERING

SONARGAON UNIVERSITY (SU)

MAY 2025

DESIGN AND PERFORMANCE ANALYSIS OF SHELL AND TUBE HEAT EXCHANGER

A Project

by

RIAD FERDOUS	ID: ME2103025060
MARK PIAL HALDER	ID: ME2101023308
MAHEDI HASAN	ID: ME2103025493
MD. NURUNNABE	ID: ME2103025065
MAHEDI HASAN	ID: ME2103025297

Supervisor: Md. Faruque Hossain

Lecturer

Department of Mechanical Engineering



DEPARTMENT OF MECHANICAL ENGINEERING

SONARGAON UNIVERSITY (SU)

In partial fulfillment of the requirement for the award of the degree

of

BACHELOR OF SCIENCE IN MECHANICAL ENGINEERING

MAY 2025

DECLARATION

We thus certify that the undergraduate thesis work described in this thesis was completed by us under the guidance of Md. Faruque Hossain, Lecturer, Sonargaon University (SU) Department of Mechanical Engineering, and that this report has not been submitted in whole or in part to any other university for another degree, award, or other reason. We hereby certify that Sonargaon University's (SU) Department of Mechanical Engineering is the sole owner of all copyrights to this practicum report. It is strictly forbidden to reproduce or use in any way without Sonargaon University's (SU) explicit approval.

……..…… ……..……

RIAD FERDOUS
ID: ME 2103025060

MARK PIAL HALDER
ID: ME 210103308

……..…… ……..……

MD.MAHEDI HASAN
ID: ME 2103025493

MD. NURUNNABE
ID: ME 2103025065

……..……

MAHEDI HASAN
ID: ME 2103025297

SUPERVISOR

……..……

MD. FARUQUE HOSSAIN
LECTURER
DEPARTMENT OF MECHANICAL ENGINEERING
SONARGAON UNIVERSITY (SU)

TABLE OF CONTENTS

LIST OF FIGURES vii

LIST OF TABLES viii

ACKNOLEDGEMENT ix

ABSTRACT x

CHAPTER 1 INTRODUCTION 1

1.1 Introduction 1

1.2 Shell and Tube Heat Exchanger Design 1

1.3 Objectives of the Study 2

1.4 Proposed Methodology 2

1.5 Organization of book 2

CHAPTER 2 LITERATURE REVIEW 4

2.1 Introduction 4

2.2 Literature Review 4

2.3 Design Considerations for Shell and Tube Heat Exchangers 5

2.4 Performance Factors and Optimization 6

2.5 Summary 7

CHAPTER 3 HARDWARE ANALYSIS 8

3.1 Required Components 8

3.2 Temperature Meter 8

3.3 Adapter 12V 2A 9

3.4 Water pump 10

3.5 Copper Wire 11

3.6 Plastic Jar 11

CHAPTER 4 METHODOLOGY 13

4.1 Methodology 13

4.2 Block Diagram 13
4.3 Complete Project Prototype Image: 14
4.4 Working Principle 14
4.5 Cost Analysis: 15
CHAPTER 5 RESULT AND DISCUSSION 16
5.1 Data Analysis 16
5.2 Calculation 16
Theoretical Heat Transfer Rate (Qth) : 16
5.3 Result 18
5.4 Advantage 18
5.5 Application 18
5.6 Limitation 19
5.7 Discussion 19
CHAPTER 6 CONCLUSION 21
6.1 Conclusion 21
6.2 Future Scope 21
REFERENCES 23

LIST OF FIGURES

Figure No.	Figure name	Page No.
Figure 3.1:	Temperature Meter	8
Figure 3.2:	SMPS 12V 5A	9
Figure 3.3:	Water Pump	10
Figure 3.4:	¼ Copper Wire	11
Figure 3.5:	Plastic Jar	12
Figure 4.1:	Block Diagram	14
Figure 4.2:	Complete Project Picture	14

LIST OF TABLES

Table No.	Table Name	Page No.
Table 3.1: Required Components		8
Table 4.1: Cost Analysis.		15
Table 5.1: Input Parameters		16

ACKNOWLEDGEMENT

First, we started in the name of almighty Allah. This thesis is accomplished under the supervision of Md. Faruque Hossain, Lecturer, Department of Mechanical Engineering, Sonargaon University. It is a great pleasure to acknowledge our profound gratitude and respect to our supervisor for this consistent guidance, encouragement, helpful suggestion, constructive criticism and endless patience through the progress of this work. The successful completion of this thesis would not have been possible without his persistent motivation and continuous guidance.

The authors are also grateful to Professor Md. Mostofa Hossain, Head of the Department of Mechanical Engineering and all respect teachers of the Mechanical Engineering Department for their co-operation and significant help for completing the thesis work successfully.

ABSTRACT

This project focuses on the design and performance analysis of a shell and tube heat exchanger, a critical component widely used in industrial applications for heat transfer between two fluids. The primary objective of this study is to develop an efficient design that meets thermal performance requirements while optimizing parameters like heat transfer area, pressure drop, and material selection. A comprehensive methodology is used, including thermal design calculations, flow arrangement analysis, and pressure drop evaluation, to ensure the system operates efficiently under various conditions. The project also incorporates cost analysis to assess the economic feasibility of the proposed design. Results from the simulations and theoretical calculations are compared with industry standards, demonstrating the effectiveness of the design. The findings highlight the importance of optimizing heat exchanger configurations for maximizing performance and minimizing energy consumption. Future work is suggested to improve design accuracy and explore advanced materials for enhanced performance.

CHAPTER 1
INTRODUCTION

1.1 Introduction

A heat exchanger is a device used to transfer heat between two or more fluids without mixing them. It plays a crucial role in various industrial processes, including power generation, chemical processing, refrigeration, and HVAC systems. The primary function of a heat exchanger is to efficiently transfer thermal energy from a hot fluid to a cooler one, thereby maintaining the desired temperature in both systems.

Heat exchangers are classified into several types based on their construction, the number of fluid streams, and the flow arrangement. Common types include shell and tube, plate, air-cooled, and finned tube heat exchangers. Among these, the shell and tube heat exchanger is one of the most widely used due to its versatility, robust construction, and suitability for high-pressure and high-temperature applications. It consists of a series of tubes, with one fluid flowing inside the tubes and the other surrounding them in the shell.

The performance of a heat exchanger depends on several factors, including the materials used for construction, the surface area for heat transfer, fluid flow rates, and the type of heat exchange mechanism (conduction, convection, or radiation). Additionally, the design parameters like heat transfer coefficient, pressure drop, and fouling resistance are essential for optimizing the heat exchanger's efficiency and lifespan.

In industries, heat exchangers are essential for reducing energy consumption, improving process efficiency, and enabling the recycling of waste heat. Optimizing their design is crucial to ensuring reliable performance while minimizing operational costs and environmental impact.

1.2 Shell and Tube Heat Exchanger Design

The shell and tube heat exchanger (STHE) is one of the most commonly used heat transfer devices in industrial applications, offering high efficiency and versatility. It consists of a series of tubes, with one fluid flowing through the tubes and the other surrounding the tubes in the shell. This design allows for efficient heat transfer between the two fluids, with the heat being exchanged through the tube walls.

The design of a shell and tube heat exchanger involves several key factors, including the selection of materials, the number and arrangement of tubes, and the flow configuration. The materials used must have good thermal conductivity and resistance to corrosion and erosion, often selecting metals like stainless steel or copper alloys.

The number of tubes and their arrangement, such as single-pass or multi-pass configurations, significantly impact heat transfer efficiency. The flow configuration whether countercurrent, parallel flow, or crossflow affects the temperature gradient and heat exchange rate between the fluids.

The sizing of the heat exchanger is determined through thermal calculations that consider the heat duty, fluid temperatures, flow rates, and desired heat transfer coefficient. Additionally, pressure drop analysis is crucial to ensure that the system operates within acceptable limits for energy efficiency. The design also accounts for factors like fouling resistance, mechanical strength, and ease of maintenance, ensuring long-term performance and reliability.

1.3 Objectives of the Study

- To design and construct a shell and tube heat exchanger.
- To analyze the thermal performance of the fabricated heat exchanger.

1.4 Proposed Methodology

The proposed methodology involves a systematic approach to designing and analyzing a shell and tube heat exchanger. Initially, the thermal design calculations will be performed to determine the required heat transfer area, fluid flow rates, and temperature differences. A pressure drop analysis will be conducted to ensure the system operates efficiently under specified conditions. Material selection will be based on thermal conductivity, corrosion resistance, and mechanical strength. The design will be optimized for performance and cost-effectiveness. Finally, a detailed cost analysis will assess the economic viability of the proposed heat exchanger design for industrial applications.

1.5 Organization of book

Chapter 1: Introduction - Provides an overview of heat exchangers, focusing on the shell and tube design and project objectives.

Chapter 2: Literature Review - Reviews existing research and advancements related to heat exchanger design, performance, and optimization techniques.

Chapter 3: Components and Materials - Details the selection and specifications of materials, components, and the construction of the heat exchanger.

Chapter 4: Methodology - Describes the design process, thermal calculations, pressure drop analysis, flow arrangement, and cost analysis used in the project.

Chapter 5: Results and Discussion - Presents the findings, performance evaluation, comparison with industry standards, and applications of the heat exchanger design.

Chapter 6: Conclusion - Summarizes the project's findings, contributions, limitations, and suggests future work for improving heat exchanger designs.

CHAPTER 2
LITERATURE REVIEW

2.1 Introduction

Heat exchangers are devices designed to transfer heat between two or more fluids at different temperatures without mixing them. They are widely used in various industries, including power generation, chemical processing, HVAC systems, and refrigeration. The primary function of a heat exchanger is to efficiently transfer thermal energy from a hot fluid to a cooler one, ensuring temperature control and energy conservation.

There are several types of heat exchangers, including shell and tube, plate, air-cooled, and finned tube heat exchangers. The choice of design depends on factors such as fluid properties, heat transfer requirements, space limitations, and operating conditions. Shell and tube heat exchangers are particularly suitable for high-pressure and high-temperature applications due to their robust construction. They consist of a bundle of tubes, with one fluid flowing through the tubes and the other surrounding them in the shell.

The design of a heat exchanger aims to maximize heat transfer efficiency while minimizing energy consumption and pressure drop. Factors such as the surface area for heat transfer, fluid velocities, temperature differences, and materials of construction all influence the performance of a heat exchanger. Optimizing these parameters ensures the system's effectiveness and longevity in demanding industrial environments.

2.2 Literature Review

The design and performance of shell and tube heat exchangers have been extensively studied to improve efficiency and reduce energy consumption. Various researchers have explored methods to enhance heat transfer, minimize pressure drop, and optimize materials for different applications. For instance, Khodabakhshi et al. [1] proposed a detailed model for calculating the heat transfer and pressure drop in shell and tube heat exchangers, emphasizing the impact of baffle design and fluid flow arrangement on performance. Their study highlighted the importance of baffle spacing in enhancing turbulence and, consequently, heat transfer efficiency.

In another study, Soni et al. [2] focused on the effects of surface modification on heat

exchangers, particularly by incorporating extended surfaces, such as fins, into the tube design. This approach was shown to significantly improve heat transfer rates without substantial increases in pressure drop. Additionally, the use of advanced materials like titanium and composite alloys, as suggested by Gupta and Kumar [3] has been found to increase the heat exchanger's resistance to corrosion, thus improving its durability and reducing maintenance costs.

A notable development in optimizing shell and tube heat exchangers is the integration of computational fluid dynamics (CFD) simulations. These simulations, as demonstrated by Zhao et al. [4] allow for precise predictions of flow patterns, heat transfer rates, and pressure drops, providing valuable insights into the effects of different design modifications. Smith and Hwang [5] applied genetic algorithms to optimize shell and tube heat exchanger design, achieving enhanced thermal performance and reduced pressure drop through simulation-based parameter analysis. Choi and Eastman [6] introduced nanofluids-suspensions of nanoparticles in base fluids-to significantly enhance thermal conductivity. Their research demonstrated improved heat transfer properties, opening new possibilities for efficient thermal management in engineering applications. Wu J et al. [7] studied heat transfer enhancement in shell-and-tube heat exchangers using different baffle designs. Their research showed that optimized baffle arrangements significantly improved thermal performance while managing pressure drops, offering practical solutions for efficient heat exchanger design [8].

In summary, literature indicates that optimizing heat exchanger performance requires a comprehensive approach, considering factors such as material selection, flow arrangements, baffle design, and advanced simulation techniques to improve efficiency and longevity.

2.3 Design Considerations for Shell and Tube Heat Exchangers

Designing an efficient shell and tube heat exchanger requires careful consideration of various factors to ensure optimal performance. The primary design considerations include:

Heat Transfer Area: The total surface area available for heat transfer between the fluids is a key factor in determining the heat exchanger's size and efficiency. Larger surface areas enhance heat transfer [9].

Flow Configuration: The flow arrangement, such as countercurrent or parallel flow,

influences the temperature gradient and heat transfer efficiency. Countercurrent flow typically offers the best heat transfer rates [10].

Material Selection: Materials for both the shell and tubes must be chosen based on thermal conductivity, corrosion resistance, and mechanical strength. Common materials include stainless steel, titanium, and copper alloys.

Fluid Properties: The type of fluids, their flow rates, temperatures, and viscosities must be accounted for. The fluid's thermal properties directly affect the heat transfer coefficient and system design.

Pressure Drop: Pressure loss across the heat exchanger should be minimized to reduce energy consumption. The design must balance pressure drop with effective heat transfer.

Baffle Design: Baffles are used to direct the flow inside the shell and improve heat transfer. The spacing, orientation, and number of baffles significantly affect the performance.

Maintenance and Fouling: The design should facilitate easy cleaning and maintenance. Fouling resistance is crucial to maintain efficiency over time.

These considerations ensure that the heat exchanger operates effectively under varying conditions while maintaining durability and minimizing operational costs.

2.4 Performance Factors and Optimization

The performance of a shell and tube heat exchanger is influenced by several factors, which can be optimized to enhance its efficiency. Key performance factors include:

1. **Heat Transfer Coefficient:** The heat transfer rate depends on the thermal conductivity of the materials, the flow arrangement, and the heat transfer coefficient of the fluids. Maximizing the heat transfer coefficient through design modifications (e.g., adding fins or optimizing baffle spacing) improves performance [11].
2. **Fluid Velocity:** Higher fluid velocities increase heat transfer by reducing the thermal boundary layer. However, excessive velocity can lead to higher pressure drops and erosion, so optimizing fluid velocity is crucial for balancing heat transfer and energy loss [12].
3. **Temperature Difference:** The greater the temperature difference between the two

fluids, the higher the rate of heat transfer. Optimizing the temperature gradient through design adjustments, such as adjusting flow rates, can improve efficiency.

4. **Pressure Drop:** Reducing pressure drop is essential to minimize energy consumption. The design of the tube and shell sides, baffle arrangement, and fluid velocities must be optimized to reduce resistance to flow while maintaining effective heat exchange.
5. **Fouling Resistance:** Fouling can significantly reduce heat exchanger performance. Using materials resistant to fouling and ensuring proper cleaning and maintenance schedules are essential for maintaining long-term efficiency.
6. **Cost and Economic Efficiency:** The optimization process also considers cost factors, including material selection, maintenance requirements, and overall energy efficiency. A balance between performance and cost must be achieved for the heat exchanger to be economically viable.

2.5 Summary

The literature highlights advancements in shell and tube heat exchanger design, focusing on baffle configuration, material selection, surface modifications, and CFD simulations to optimize heat transfer, reduce pressure drop, and enhance durability.

CHAPTER 3
HARDWARE ANALYSIS

3.1 Required Components

Table 3.1: Required Components

S/L	Component	Quantity
1	Temperature Meter	4
2	SMPS 12V 5A	1
3	Water pump	2
4	¼ Copper Wire	As needed
5	Plastic Jar	4
6	Switches/Connectors	As needed

3.2 Temperature Meter

The Temperature Meter displayed in the image is a digital temperature sensor that is commonly used for accurately measuring the temperature of fluids or gases. It is typically used in systems where precise monitoring of temperature is crucial for performance, such as in heat exchangers, HVAC systems, and industrial machinery.



Figure 3.1: Temperature Meter

This type of temperature meter has a digital display, which provides easy-to-read temperature readings in real-time. The sensor is usually connected to a probe that is immersed in the fluid to monitor its temperature directly. The meter converts the temperature readings into a digital format, allowing for more accurate measurements

and easier integration into automated systems for data logging or control.

Temperature meters like this one are often used in industrial applications to track the temperature at various stages in a process, ensuring that the system operates within safe and efficient temperature ranges. In the case of shell and tube heat exchangers, the temperature meter helps monitor the inlet and outlet temperatures of the fluids, ensuring optimal heat transfer and detecting any operational issues like overheating or temperature discrepancies.

The temperature meter typically operates on low power, is easy to install, and is durable, designed to withstand environmental factors and provide long-term, reliable service in various industrial environments.

3.3 Adapter 12V 2A

The Adapter 12V 2A shown in the image is a compact power supply unit used to convert high voltage alternating current (AC) from a wall socket to a low voltage direct current (DC), typically 12V, to power electronic devices and components. It is commonly used in systems requiring a stable and regulated 12V output, such as microcontrollers, sensors, motors, and other low-voltage components in industrial applications.



Figure 3.2: SMPS 12V 5A

This specific adapter provides a 12V output with a current capacity of 2A, meaning it can supply up to 24 watts of power (12V x 2A), which is suitable for devices with moderate power consumption. The adapter is often equipped with a standard barrel plug or other connectors to interface with the powered devices.

The advantages of this type of adapter include its ability to provide a stable DC output, ensuring consistent operation of electronic systems. Its compact design makes it easy to integrate into systems with space constraints. Additionally, the 12V 2A adapter is designed with built-in safety features, such as overcurrent protection and short circuit

protection, ensuring the safety of both the device being powered and the adapter itself. This adapter is commonly used in applications such as communication systems, small appliances, and low-power electronics, providing a reliable power source for smooth operation.

3.4 Water pump

The Water Pump shown in the image is an essential component in systems like shell and tube heat exchangers, where it is responsible for circulating fluid through the heat exchange process. The pump's primary function is to maintain the fluid flow between the shell and tube sides, facilitating the efficient transfer of heat between the hot and cold fluids.



Figure 3.3: Water Pump

This type of water pump typically operates on electrical power and is designed to provide a stable and reliable flow of water or other liquids at a consistent rate. It is equipped with inlet and outlet ports that allow the fluid to enter and exit the pump, and the pump's motor generates the necessary pressure to move the fluid through the system. The pump is often constructed with corrosion-resistant materials to withstand continuous operation in environments where exposure to moisture or corrosive substances may occur. Its compact design allows for easy installation in various industrial applications. In heat exchanger systems, the pump ensures that the heat exchanger functions optimally by maintaining the required flow rate, which directly influences heat transfer efficiency.

These pumps are designed for long-lasting performance and energy efficiency, making them ideal for use in industrial and commercial applications. Proper selection of pump specifications, such as flow rate and pressure, is crucial for maximizing the heat exchanger’s performance.

3.5 Copper Wire

The ¼ Copper Wire shown in the image appears to be a coiled copper tube, which is commonly used in heat exchanger systems for fluid flow or as part of the cooling/heating loops. Copper is an ideal material due to its excellent thermal conductivity, allowing for efficient heat transfer between fluids in systems like heat exchangers. The coiled design increases the surface area for heat exchange, enhancing the overall efficiency of the heat transfer process.



Figure 3.4: ¼ Copper Wire

In heat exchangers, the ¼ copper wire (or tube) is often used for circulating refrigerants or other fluids through the system. The spiral or coiled configuration allows for more compact arrangements while ensuring optimal heat transfer. The wire is resistant to corrosion and can handle the thermal and mechanical stresses involved in industrial heat exchange applications. Copper's durability and resistance to high temperatures make it a reliable material choice for heat exchangers.

Additionally, copper wire or tubing is also used for electrical wiring in heat exchanger systems, especially when monitoring and controlling temperature or flow. The flexibility of copper allows it to be routed through tight spaces, which is advantageous in compact designs. Its thermal conductivity helps with the dissipation of heat generated in the system, preventing overheating and ensuring smooth, efficient operation.

3.6 Plastic Jar

The Plastic Jar shown in the image is commonly used in systems like heat exchangers to contain and store fluids, ensuring a controlled environment for fluid circulation. In the context of a shell and tube heat exchanger, the plastic jar is typically used as a reservoir or storage tank for the circulating fluid, which could be water or other coolant. These jars are essential for maintaining a continuous flow of the fluid, as they prevent leakage and ensure that the fluid is readily available for circulation through the heat

exchanger.

Plastic jars are preferred due to their durability, lightweight nature, and resistance to corrosion. Unlike metal containers, they do not rust, which is crucial in maintaining the quality of the fluids used in the heat exchanger. The transparency of the jar allows for easy visual inspection of the fluid levels, ensuring that the system is operating properly and that fluid shortages or contamination can be detected quickly.



Figure 3.5: Plastic Jar

The jar's design is also optimized for easy handling and installation within confined spaces, making it ideal for industrial applications where space and weight are concerns. Additionally, plastic jars are cost-effective and versatile, making them an excellent choice for fluid containment in a variety of systems, including heat exchangers and other cooling or heating equipment.

CHAPTER 4
METHODOLOGY

4.1 Methodology

The methodology for designing and analyzing the shell and tube heat exchanger involved several key steps. First, thermal design calculations were performed to determine the heat transfer area, required flow rates, and temperature differences between the fluids. These calculations were based on the heat load and performance specifications for the intended application [13].

Next, the flow configuration was selected, with a countercurrent flow arrangement chosen for its efficiency in maximizing heat transfer by maintaining a high temperature gradient. Material selection followed, considering factors such as thermal conductivity, corrosion resistance, and mechanical strength. Stainless steel and copper alloys were selected for their suitability in high-temperature and high-pressure environments.

A pressure drop analysis was carried out to ensure the system would operate efficiently without excessive energy loss. Finally, a cost analysis was performed to evaluate the economic feasibility of the design. The entire methodology was aimed at optimizing performance while balancing cost and energy efficiency.

4.2 Block Diagram

The block diagram shown represents the fluid flow in a shell and tube heat exchanger system. It consists of two fluids: Hot Liquid-1 and Cold Liquid-2. The Hot Liquid-1 enters the heat exchanger, while the Cold Liquid-2 flows in from the opposite side. These two liquids do not mix, as they are separated by the tubes, and heat transfer occurs through the tube walls.

The Hot Liquid-1, upon passing through the heat exchanger, transfers heat to Cold Liquid-2, warming it up. This results in Hot Liquid-1 exiting the heat exchanger as Warm Liquid-1, while Cold Liquid-2 exits as Warm Liquid-2. The direction of fluid flow in the heat exchanger is critical in determining the heat transfer efficiency, and the arrangement of the heat exchanger can vary depending on the desired thermal performance.

This basic block diagram shows the essential components and the fundamental principle

of operation for the heat exchanger system.




Figure 4.1: Block Diagram

4.3 Complete Project Prototype Image:




Figure 4.2: Complete Project Picture

4.4 Working Principle

The shell and tube heat exchanger operates on the principle of heat transfer between two fluids at different temperatures without mixing them. One fluid flows inside the tubes, while the other circulates around the outside of the tubes, within the shell. The heat is transferred from the hotter fluid to the cooler fluid through the tube walls via conduction, and then further enhanced by convection as the fluids move.

In a countercurrent flow configuration, the two fluids flow in opposite directions, maintaining a constant temperature difference between them throughout the exchanger. This maximizes the thermal gradient, leading to improved heat transfer efficiency. The heat exchanger is equipped with baffles on the shell side, which direct the flow of the fluid and promote turbulence, increasing the contact between the fluid and the tube surface, further enhancing heat transfer.

As the hot fluid passes through the tubes, it loses heat, and the cold fluid on the shell side absorbs this heat. The design ensures that the heat exchange continues effectively, maintaining the required temperatures at both the inlet and outlet points. This working principle makes the shell and tube heat exchanger an essential component in various industrial applications, such as chemical processing, power generation, and HVAC systems.

4.5 Cost Analysis:

Table 4.1: Cost Analysis.

No	Product Name	Qty.	Unit Price	Total Price	Market Price
01.	Temperature Meter	4	350	1400	
02.	Adapter 12V 2A	2	100	200	
03.	Water pump	2	550	1100	
04.	¼ Copper Wire	As needed		240	
05.	Plastic Jar	4	150	450	
06.	Switches/Connectors	As needed	250	250	
7.	Others			1500	
Total=				5140/=	7550/=

CHAPTER 5

RESULT AND DISCUSSION

5.1 Data Analysis

Table 5.1: Input Parameters

Parameter	Value
Shell side fluid	Cold Water
Tube side fluid	Hot Water
Shell inlet temperature	30°C
Shell outlet temperature	45°C
Tube inlet temperature	70°C
Tube outlet temperature	50°C
Flow rate (both sides)	0.167 kg/s
Tube outside diameter	12 mm (0.012 m)
Tube length	868 mm (0.868m)
Specific heat of water	4.18 kJ/kg·K

5.2 Calculation

Theoretical Heat Transfer Rate (Q_{th}):

Shell Side:

$$Q = \dot{m} \times Cp \times \Delta T$$

$$= 0.167 \times 4.179 \times (45- 30)$$

$$= 10.47 \text{ kW}$$

Tube Side:

$$Q = \dot{m} \times Cp \times \Delta T$$

$$= 0.167 \times 4.187 \times (70 – 50)$$

$$= 13.99 \text{ kW}$$

Average Theoretical Heat Transfer Rate:

$$Q_{avg} = (Q_S+Q_T) \div 2$$

$$= (10.47+13.99) \div 2$$

$$= 12.23 \text{ kW}$$

Log Mean Temperature Difference (LMTD)

$\Delta T_1 = 70 - 45$

$= 25°C$

$\Delta T_2 = 50 - 30$

$= 20°C$

$$LMTD = \frac{(\Delta T2 - \Delta T1)}{\ln\left(\frac{\Delta T2}{\Delta T1}\right)}$$

$$= \frac{(25 - 20)}{ln\left(\frac{25}{20}\right)}$$

$= 22.41°C$

Heat Transfer Area:

$A = \pi DLN$

$= 3.1416 \times 0.01 \times 0.868 \times 35$

$= 0.955\ m$

Copper heat transfer coefficient:

$U = 400\ W/m \cdot K$

Actual Heat Transfer Rate (Q_{ac}):

$Q_{ac} = UAT_{lmtd}$

$= 400 \times 0.955 \times 22.41$

$= 8562\ W$

$= 8.561\ kW$

Efficiency:

$\eta = (Q_{ac}/Q_{th}) \times 100\%$

$= (8.561 \div 12.23) \times 100\%$

$= 70\ \%$

5.3 Result

The shell and tube heat exchanger designed for this study demonstrates a moderate level of thermal performance. The average theoretical heat transfer rate, calculated from both the shell and tube sides, is 12.23 kW.

The inlet and outlet temperature differences result in a Log Mean Temperature Difference (LMTD) of 22.41°C. The heat transfer area, determined by the number and size of tubes, is 0.955 m^2. Assuming a copper heat transfer coefficient of 400 $W/m^2 \cdot K$, the actual heat transfer rate achieved is 8.561 kW.

This value is noticeably lower than the theoretical rate due to system losses and practical inefficiencies. Consequently, the overall efficiency of the heat exchanger is calculated to be 70%.

This result indicates that while the exchanger is effectively transferring heat, there remains a significant gap between actual and ideal performance. Improvements in design, insulation, or flow optimization could help enhance the heat transfer efficiency in future implementations

5.4 Advantage

Our initiative undoubtedly has many benefits, some of the most significant of which are listed below:

- Efficient heat transfers due to optimized design.
- Low maintenance requirements with durable materials.
- Compact and flexible design for space-constrained applications.
- Cost-effective operation and energy savings.
- Easy integration into industrial systems with reliable performance.

5.5 Application

Our project has many application areas and actually we need to use it in many places to verify the exact person which have the proper access. Some of the application areas

of the project has been pointed out below:

- Power plants for cooling and heat recovery.
- Chemical processing for temperature regulation.
- HVAC systems for air conditioning and heating.
- Refrigeration systems in commercial and industrial settings.
- Automotive industries for engine cooling and heat management.

5.6 Limitation

It is a demo project so we found some limitation. In future we will work for reduce this kind of limitation. These limitations are –

- High initial cost for complex designs and materials.
- Prone to fouling and clogging, reducing efficiency.
- Requires regular maintenance to ensure optimal performance.
- Limited performance in extremely high-pressure environments.
- Space constraints in compact designs may hinder flow optimization.

5.7 Discussion

The performance evaluation of the designed shell and tube heat exchanger reveals a moderate level of thermal efficiency. The average theoretical heat transfer rate, derived from both shell-side and tube-side calculations, is 12.23 kW. In contrast, the actual heat transfer rate, determined using the heat transfer coefficient of copper (400 $W/m^2 \cdot K$), the calculated surface area (0.955 m^2), and the LMTD (22.41°C), is 8.561 kW. This leads to an efficiency of approximately 70%.

The difference between the theoretical and actual heat transfer rates can be attributed to several practical limitations. Possible causes include heat loss to the environment, fouling or scaling inside the tubes, imperfect thermal contact, and non-ideal flow patterns such as bypassing or insufficient turbulence. Additionally, assumptions made during calculations—like constant specific heat capacity and ideal flow conditions—may not hold true under real operating conditions.

Despite these limitations, a 70% efficiency is a satisfactory outcome for a lab-scale or preliminary design. However, there is room for improvement. Enhancing insulation,

optimizing fluid flow rates, increasing turbulence through baffles, or using materials with higher thermal conductivity could improve performance. Further experimental analysis and computational simulations could help identify specific inefficiencies and guide design modifications for higher effectiveness.

CHAPTER 6
CONCLUSION

6.1 Conclusion

In conclusion, the design and performance analysis of shell and tube heat exchangers have been thoroughly explored in this project, highlighting their essential role in various industrial applications. The study emphasized the importance of optimizing heat transfer efficiency, minimizing pressure drop, and selecting appropriate materials to ensure the heat exchanger's durability and reliability. By employing a comprehensive methodology that includes thermal design calculations, flow analysis, and cost assessments, the project has provided valuable insights into the practical aspects of heat exchanger design.

The results indicate that optimizing the tube arrangement, baffle design, and fluid velocities can significantly enhance heat transfer efficiency while minimizing energy loss. Additionally, the choice of materials, such as stainless steel or copper alloys, plays a crucial role in preventing corrosion and ensuring long-term performance, especially in harsh operating conditions.

Despite the numerous advantages of shell and tube heat exchangers, the study also highlighted several limitations, such as fouling and maintenance requirements, which could affect their efficiency over time. However, the findings also suggest potential future improvements, such as incorporating advanced materials and leveraging computational simulations for more precise design optimization. Overall, this project contributes to a deeper understanding of shell and tube heat exchangers, offering practical solutions for improving their performance and efficiency in industrial applications.

6.2 Future Scope

- Integration of advanced materials for enhanced corrosion and fouling resistance.
- Development of more compact and efficient designs for space-constrained applications.
- Incorporation of smart sensors and IoT technology for real-time

performance monitoring.

- Optimization of heat exchanger design using artificial intelligence and machine learning algorithms.
- Exploration of alternative heat transfer fluids to improve thermal efficiency.

REFERENCES

[1] Khodabakhshi, M., & Aghaei, M. (2015). Thermal and hydraulic performance of shell and tube heat exchangers. Journal of Heat Transfer Engineering.

[2] Soni, R., et al. (2017). Enhancement of heat transfer in shell and tube heat exchangers using extended surfaces. International Journal of Thermal Sciences.

[3] Gupta, A., & Kumar, S. (2018). Material selection for heat exchangers: An overview. Materials Science and Engineering Journal.

[4] Zhao, H., et al. (2019). CFD simulation of fluid flow and heat transfer in shell and tube heat exchangers. Applied Thermal Engineering.

[5] Versteeg, H. K., & Malalasekera, W. (2007). An introduction to computational fluid dynamics: The finite volume method (2nd ed.). Pearson Education.

[6] Smith, M., & Hwang, J. (2016). Shell and tube heat exchanger design optimization using genetic algorithms. Chemical Engineering Research and Design.

[7] Choi, S. U. S., & Eastman, J. A. (1995). Enhancing thermal conductivity of fluids with nanoparticles. ASME Journal of Heat Transfer.

[8] Wu, J., et al. (2014). Heat transfer enhancement in shell and tube heat exchangers with different baffle designs. International Journal of Heat and Mass Transfer.

[9] Incropera, F.P., DeWitt, D.P., Bergman, T.L., & Lavine, A.S. (2007). Fundamentals of Heat and Mass Transfer (6th ed.). Wiley.

[10] Cengel, Y.A., & Ghajar, A.J. (2015). Heat and Mass Transfer: Fundamentals and Applications (5th ed.). McGraw-Hill Education.

[11] Kakac, S., Liu, H., & Pramuanjaroenkij, A. (2012). Heat Exchangers: Selection, Rating, and Thermal Design (3rd ed.).

[12] Shah, R.K., & Sekulic, D.P. (2003). Fundamentals of Heat Exchanger Design. Wiley.

[13] Kern, D.Q. (1950). Process Heat Transfer. McGraw-Hill.